CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0067:120 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932 LISTEE:

Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Models CP-2ER and CP-2HR noncoded, automatic, manual and releasing device fire

> alarm control unit. May be used with normally open manual discharge station, closed abort station, cylinder pressure switch, manifold discharge monitor, Halon release circuit, auxiliary common trouble, common alarm, and common predischarge/discharge dry relay contacts. Model CP-2ER is power-limited status with the manual discharge and abort circuits of initiating zones A and B. To achieve power limited audible circuits, the PLM-35

Module must be used. Refer to listee's data sheet for additional detailed product

description and operational considerations.

RATING: 120 VAC, 60 Hz primary and 24 VDC standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and

indicating devices. Suitable for releasing service as permitted per codes.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacture's Installation Manual for

details.

*Rev 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 18, 2004 Listing Expires June 30, 2005 Date Issued:

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager